检 测 报 告

No.IOB1RBZF85372955

委托单位	仙桃绿色东方环保发电有限公司
受测单位	仙桃绿色东方环保发电有限公司
报告日期	2020 年 08 月 11 日

PONY 谱尼测试

Pony Testing International Group

www.ponytest.com

The report is invalid in case of illegal transfer, embezzlement, imposture, modification or any altering, reproducing except in
without approval of PONY. PONY shall investigate and affix the applicant's legal liability accordingly.

▲ 防伪说明 Anti-counterfeiting Description:

(1) 报告编号为唯一码;
The test report has exclusive report code.

(2) 报告采用防复印制版纹路印制，纸张上的荧光"PONY"字样为安全印，此防伪纹路受复印影响，即复制件不会带有"PONY"防伪纹路。
The test report is printed by anti-copying pattern surface effect, "PONY" security print with specific anti-counterfeiting technique. Security print will disappear after copying. Duplicates are not expected to give "PONY" security print under any circumstances.

全国服务热线
400-819-5688

扫描二维码
关注谱尼测试微信
公众号PONY-400819568

北京实验室：(010) 84158001 沈阳实验室：(024) 8[illegible]127 哈尔滨实验室：(0451)58627755
上海实验室：(021) 64851999 长春实验室：(0431)85150908 石家庄实验室：(0311)85376660 温州实验室：(0577)88271060
青岛实验室：(0532)88700866 大连实验室：(0411)87330018 乌鲁木齐实验室：(0991) 6684186 合肥实验室：(0551)63843474
深圳实验室：(0755)26050909 郑州实验室：(0371)69350670 呼和浩特实验室：(0471) 3450025 广州实验室：(020) 89224310
天津实验室：(022) 23607888 西安实验室：(029) 89608785 杭州实验室：(0571)85806807 厦门实验室：(0592)5568048
苏州实验室：(0512)62991900 太原实验室：(0351)7355762 宁波实验室：(0574)87977185 成都实验室：(028) 87702708

[redacted]	[redacted]		
[redacted]	[redacted]		
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	

检测类别	委托检测	检测环境	符合要求
样品来源	采样		
检测项目	热灼减率		
检测方法	固体废物 热灼减率的测定 重量法 HJ 1024-2019		
所用主要仪器	电子分析天平、电热鼓风干燥箱、箱式电炉		
备注	1. 该报告中检测方法由委托单位指定； 2. 限值标准：GB 18485-2014 [redacted]《生活垃圾焚烧污染控制标准》表 1。		

	编制人	徐敏文
	审核人	[redacted]
PONY 专用章	批准人	[redacted]
	签发日期	2020年08月11日

检测结果

No. IOB1RBZF85372955

样品编号及名称	检测项目	限值	检测结果
F85372955 1号炉炉渣	热灼减率，%	≤5	3.2

——以下空白——